

Conference Paper SNMREC/CP-10-347

December, 2010

**Power Availability in the Florida Current and
Impact of its Extraction on the Gulf Stream**

Alexandra Bozec

Eric Chassignet, Howard P. Hanson

Fall Meeting, 2010

American Geophysical Union

San Francisco

Southeast National Marine Renewable Energy Center

College of Engineering and Computer Science / Florida Atlantic University

Alexandra Bozec¹, Eric Chassignet¹, Howard P. Hanson²

(abozec@coaps.fsu.edu)

¹Center for Ocean-Atmospheric Prediction Studies, Florida State University, Tallahassee, FL, USA


²Center for Ocean Energy Technology, Florida Atlantic University, Dania Beach, FL, USA

GOALS OF THE PROJECT

The goals of the project are:

- ✓ to assess (and eventually predict) the power availability in the Florida Current
- ✓ to assess the impact of turbines on the Florida Current/Gulf Stream system (**First Results**)

HYCOM GLOBAL CONFIGURATION



✓ From Jun 2007 to Oct 2009 for this particular experiment (Expt 74.2)

✓ 1/12° (~7 km) horizontal resolution at 27°N

✓ 32 hybrid-layers (combination of geopotential, isopycnal, sigma layers)


✓ Navy Operational Global Atmospheric Prediction System (NOGAPS) 0.5° resolution

✓ Navy Coupled Ocean Data Assimilation (NCODA) system

<http://www.hycom.org/dataserver>

HYCOM vs. CABLE TRANSPORT

Fig. 2: Northward Transport at 27°N from the Cable (black), from HYCOM (green) and from HYCOM increasing the velocity by 10% (blue).



Monthly Transport:

- ✓ Negative bias:
Cable: ~ 32Sv
HYCOM: ~ 28Sv
HYCOM+ 10% vel: ~ 31Sv

✓ Similar variability

VELOCITY and POWER DENSITY at 27°N




Fig. 3: Northward velocity at 27°N from mooring Apr1982-Jul1984 (Leaman et al., 1987 on the left), northward velocity from HYCOM for December 2008 (middle) and the derived power density (right).

✓ The model reproduces well the structures of the current at 27°N.

✓ Maximum power density in the first 500m, 50km from the Florida Coasts : between 1.1kW/m² in Sep 2008 to 3.8kW/m² in Dec 2008.

TOTAL POWER AVAILABILITY




Fig. 4: Evolution of the Total Power Availability sorted by velocity or Rotor minimum speed over the 27°N section (data from HYCOM + 10%).

- ✓ Semi-annual variability.
- ✓ Max/Min in Dec/Sept 2008.

- ✓ Best efficiency : At best ~ 60% of the energy can be captured.
- ✓ Strong variability of the available power : From 1GW to 10GW.

N.B.: 1GW=1 nuclear power plant




Fig. 5: Evolution of the power availability for velocity (or rotor minimum speed) greater than 1.5m/s.


HYCOM ATLANTIC CONFIGURATION FOR TURBINES SIMULATIONS

Atlantic configuration of HYCOM :

- ✓ 1/12° horizontal resolution
- ✓ 32 hybrid layers
- ✓ Initial conditions (T,S) from GDEM3
- ✓ Climatological ERA40 atmospheric forcing
- ✓ 2 Simulations starting from a 10 year run :

- ✓ 1 control simulation
- ✓ 1 simulation with "4 turbines" at 20m parameterized as a drag :

First Test: $C_T = 1$ (Only 5 months available for now)



$$-\frac{1}{2} C_T \sqrt{U^2 + V^2}$$

TURBINES in the FLORIDA CURRENT (1)





Fig. 6: Kinetic Energy in CONTROL (top) for day 1 at 20m. Difference of kinetic energy between CONTROL and TURBINES for day 1.

- ✓ 4 "turbines" in the Florida Current at 25.7°N.


Fig. 7: Difference of Kinetic Energy between the CONTROL and TURBINES simulations (Average over the 5th month).

- ✓ Impact on the path of the current **upstream and downstream** but not in intensity.



TURBINES in the FLORIDA CURRENT (2)

Fig. 7: Northward velocity section at 25.7°N for CONTROL (top) and TURBINES (bottom) at day 101. Black contours are layer interfaces of HYCOM.



- ✓ Disturbance of the flow over the whole section.





Fig. 8: Evolution of the total power available over the whole section at 25.7°N for CONTROL and TURBINES (top) and the difference (bottom).


- ✓ The presence of turbines impacts the power available over the whole section (even increasing it).



- ✓ Estimation of the power extracted only by the 4 "turbines" (power extracted over the 4 grid cells): 400MW to 800MW.

N.B.: 1MW=1000 homes

- ✓ Impact on the Upstream and Downstream Transport



- ✓ Little impact on the total transport of the flow downstream and upstream (except for few days in the downstream transport).

Fig. 9: Evolution of the transport at 29.2°N (top) and 80.9°W (bottom) for CONTROL and TURBINES.

FUTURE WORK

- ✓ Continue the simulation to complete a year.
- ✓ Test different C_T number.
- ✓ Impact of turbines on the energetics of the Florida current/Gulf Stream system.
- ✓ Develop a realistic high-resolution configuration of the Fort Lauderdale region (with assimilation).